

Avoid overheating, cycling, carbon buildup and extra cleaning. If your MCPS doesn't have air duct openings, install the tent wall modification kit, NSN 4520-01-493-3215. The kit allows you to cut openings in the shelter wall and to add a sleeve to seal around the ducts. Attaching the supply and return ducts to the openings lets air flow freely through the space heater.




YOU'LL FIND COMPLETE INSTRUCTIONS FOR INSTALLING THE KIT IN WORK PACKAGE 0005 OF TM 10-4520-262-12&P.

You can still use your space heater while you're waiting for the kit to arrive. Just make sure you prop up the shelter wall so it doesn't squeeze the supply and return ducts and restrict airflow.



Cut duct openings in shelter wall...



...then supply and return ducts let air flow freely

PS END

## Rope Lock NSN



Use a rope lock, NSN 4030-01-477-0524, to keep a tent rope, loose gear, flight line or canvas cover snug. The rope lock doesn't need continual adjustments once it's secured or fastened in place. This NSN gets a package of 12 rope locks.