

3-KW TQG...

# Getting a Good Start

WE NEED A NEW 24-VOLT STARTER FOR THIS GENERATOR.

ORDER IT, JONES!

YES, SIR.

2-3 WEEKS LATER...

THIS IS A 12-VOLT STARTER! JONES!

I DIDN'T SCREW UP!

LOOK! IT'S THE NSN THAT'S WRONG!

WHATEVER. WE NEED THAT GENERATOR WORKING.

HEY! BE RIGHT BACK!

TAH-DAH!

WHERE'D YOU GET THAT!?

FROM THE 2-KW SUPPLIES. THE SAME STARTER WORKS FOR BOTH!

THE OLD NSN IS BAD -- IT HAS BEEN CHANGED!

If you've been using NSN 2920-21-910-1201 to order a starter for your 3-KW tactical quiet generator (TQG), stop it. That NSN bit the dust because it brought a 12-volt one and your generator needs a 24-volt one.

To get a 24-volt starter for your 3-KW TQG, use NSN 2920-01-452-8409. So, wherever you have the old NSN squirreled away, unsquirrel it, pitch it and replace it with this new NSN.

If your unit has 2-KW TQGs, you may already have the starter in supply. The same starter is now used on both the 2 and 3.

Stay on your toes, though, about this issue. There are plans in the works to obtain an additional starter for the 3-KW with a new NSN. If and when it happens, we'll tell you about it!