


Safety of Use
Messages...

Stay **WARM** and **SAFE** This Winter

THE USAMC
COMMUNICATIONS-
ELECTRONICS
COMMAND HAS
RELEASED A
SAFETY OF USE
MESSAGE.

FOR THOSE OF YOU
LOOKING TO STAY
COMFORTABLE IN
SHELTERS YEAR-
ROUND, THIS WILL
BE OF **PARTICULAR**
INTEREST.



CECOM SOUM #05-001

CECOM SOUM #05-001 concerns the field deployable environmental control unit (FDECU), models FDECU-2, FDECU-3, FDECU-4 and FDECU-5, NSN 4120-01-449-0459, LIN A26852.


The FDECU provides cooled or heated air to various types of portable shelters and vans.

The reason for the SOUM is that a few soldiers suffered smoke inhalation when the heater assembly, P/N 9454066, NSN 4520-01-494-3852, of a FDECU overheated and their tent filled with smoke. The Army believes worn wiring insulation caused the overheating.

Unit maintainers must inspect the heater assembly. Follow the procedures in Item No. 6 of the unit PMCS in TM 9-4120-411-14.

Read the complete SOUM for the full story. It's available at the Army Electronic Product Support (AEPS) website:

<https://aeps2.ria.army.mil/commodity/soum/cecom/05/csoum05-01.html>



IF YOU
HAVE ANY
QUESTIONS
ABOUT THIS
SOUM, CON-
TACT THESE
TWO POCs...



[dono.oglesby@
us.army.mil](mailto:dono.oglesby@us.army.mil)

DSN 987-7473
(732) 427-7473

DSN 992-3990
(732) 532-3990