


RETURN FUEL LINES

I NEED TO REPLACE MY RETURN FUEL LINE, BUT I CAN'T FIND THE NSN!

WHY AM I DOING MY OWN MAINTENANCE, ANYWAY!?



Dear Editor,

The 5-KW DED, NSN 2815-01-350-2205, and the 10-KW DED, NSN 2815-01-350-2206, tactical quiet generators need 10 feet of return fuel lines.

According to the 5-KW engine manual, TM 9-2815-252-24P, and the 10-KW manual, TM 9-2815-253-24P, you make the return fuel lines from bulk stock. The bulk stock they give you is part number 503-1052. You can find that as Item 3 in Fig 5.

Unfortunately, that part number does not bring an NSN on FED LOG.


Fortunately, we were able to find an NSN that brings the nonmetallic hose by the foot. It's NSN 4720-01-483-6467.

I thought you would like to put this in PS.

SFC
DEARNG

Editor's note: You thought right, Wayne! Generator mechanics, if you're doing maintenance on these engines, check the return fuel lines. If they need replacing, you now have an NSN to order more hose.

IT COMES IN A ROLL.



Characteristics Data Response for NSN 4720-01-483-6467
Item Name: HOSE, NONMETALLIC

MRC	Requirement Statement	Clear Text Reply
NAME	ITEM NAME	HOSE, NONMETALLIC
AAGR	CROSS-SECTIONAL SHAPE STYLE	1 ROUND
AARX	INSIDE DIAMETER	0.14 INCHES NOMINAL
ADJM	INNER CONVEYING TUBE MATERIAL	RUBBER, BUNA-IN
CQCS	LAYER COMPOSITION AND LOCATION	OUTER LAYER BRAIDED COTTON CORD
CRWL	INSIDE SURFACE CONDITION	SMOOTH
MEDA	MEDIA FOR WHICH DESIGNATED	FUEL/OIL, HYDROCARBON AND WATER AND AIR